

Minutes
Electrical Board of Appeals and Examiners
Building Services Conference Room
January 6, 2010, 1:30 p.m.

Members Present

Mark Anderson, Eric Pauli, Dave Thompson, Todd Weidner, and Clerk Tom Fields

Members Absent

Darrin Skyberg

Guests Present

Ron Bell, Don Hall, Larry Kippes, and George Bunkers

Approval of Minutes of Last Meeting

A motion was made by Dave Thompson and a second was made by Mark Anderson to approve the minutes of December 2nd, 2009. Yeses, 4. Noes, 0.

Unfinished Business

1. None

New Business

1. Appeal No. 1-2010. George Bunkers of Bunkers Construction presented to the Electrical Board a drawing showing receptacles approximately 3 feet apart above a kitchen counter at 4804 South Yellowstone Circle. He felt that this was a sufficient number of receptacles and that it wasn't necessary to have receptacles within 2 feet of the kitchen sink. He requested the Board members review and okay the installation. Don Hall presented a brief history of how this Article 210.52 evolved to the current code requirements, and that is why it is necessary to have receptacles within 24 inches of the kitchen sink.

A motion was made by Todd Weidner and a second was made by Dave Thompson to deny the Appeal No. 1-2010. Yeses, 4. Noes, 0.

Adjournment

A motion was made by Mark Anderson and a second was made by Dave Thompson to adjourn the meeting at 2:20 p.m. Yeses, 4. Noes, 0.

Tom Fields, Electrical Board Clerk